

Office of the District Fire Officer
Karnataka State Fire
and Emergency Services
Khanapur Road, Belagavi-590001



Phone : 0831-2429441
E-Mail : dfobgv@gmail.com

C.NO/37/FSCR/DFO/BELAGAVI/2025

Date : 24-04-2025

To,
The Chairperson & Managing Trustee,
People's Education Society & Trust's,
Shaikh Central School,
Shaikh Campus, Nehru Nagar,
Belagavi, Belagavi Taluka & District.

Sir,

Sub: Issue of "**Fire Safety Compliance Report**" to People's Education Society & Trust's, Shaikh Central School, Shaikh Campus, Nehru Nagar, Belagavi, Belagavi Taluka & District.

Ref: 01) SGES/EEC/LTR-270/24-25 Dated:24/04/2025

02) C.NO/37/FSR/DFO/BELAGAVI/2025 Date: 10-02-2025.

----*--*--*

With reference to the subject above cited, the premises of **People's Education Society & Trust's, Shaikh Central School**, building consisting with **Ground & 03 Upper floors situated at Shaikh Campus, Nehru Nagar, Belagavi, Belagavi Taluka & District.** was inspected by The District fire Officer Belagavi on 24/04/2025 with respect to fire Prevention, Fire Fighting & Evacuation point of view for the purpose of issuing Issue of **Fire Safety Compliance Report** and has submitted the details as under.

ANNEXURE-1

"GROUP-B Educational Buildings

NBC-2016, Part-4, Table 7 (11) 3.1.3 Group B Educational Buildings Sub division B1 & B2.

(These condition are indicative and not exclusive all relevant provisions related to fire and life safety of NBC 2016 are mandatory.)

A. Details of the Building/Premises.

01	Name and Address of the Applicant	The Chairperson & Managing Trustee, People's Education Society & Trust's, Shaikh Central School, Shaikh Campus, Nehru Nagar, Belagavi, Belagavi Taluka & District.
02	Name and Address of the Premises	Shaikh Central School, Shaikh Campus, Nehru Nagar, Belagavi, Belagavi Taluka & District.
03.	Name and Address of the Building Owner	The Chairperson & Managing Trustee, People's Education Society & Trust's Nehru Nagar, Belagavi, Belagavi Taluka & District.
04.	Number of Building	01
05.	Number of Floors	Ground & 03 Upper Floors

(Signature)
25/04/25

06.	Floor-wise details of Occupancy:-	
	Ground Floor	Shaikh Central School Class Room-13, Office Room-01, Laboratory-03, Store Room-01, Reading Room-01, Meeting Room-01 Library room-01.
	1 st Floor	Class Room-14, Computer Lab-02, Chemistry lab-01, Staff Room-02, Office Room-03, Sports Room-01.
	2 nd Floor	Shaikh Pre-University College of Science, Commerce & Arts Class Room-03, Laboratory Room-02, Language Room-01, Library Room-01, Ladies Room-01, Office Room-02, Reception Room-01.
	3 rd Floor	Class Room-04, Laboratory Room-03, Computer Lab-01, Store Room-01.
07.	Height of the building	14.50 Mtr
08.	Site area	04 Acre
09.	Built-up area of each floor:-	
	Ground Floor	1407.46 Sq Mtr.
	1 st Floor	1399.86 Sq Mtr.
	2 nd Floor	864.80 Sq Mtr.
	3 rd Floor	864.80 Sq Mtr.
10.	Total Built-up area	4536.92 Sq Mtr.
11.	Surrounding properties:-	
	East	Service Road.
	West	Open Ground.
	North	S.G.Balekundri College.
	South	Service Road.
12.	Open Space all around the building	
	East	Attached To The Road
	West	Open Ground
	North	02.75 Mtr
	South	Nil
Allowed Setbacks (open space) should be maintained free from further obstruction/construction.		

B. On the inspection of this School/College premises, the following Fire Prevention, Fire Fighting and Evacuation Measures recommended are considered absolutely essential from fire safety point of view:-

Sl. No (01)	Details (02)	Existing (03)	Recommendations (04)
01.	Accessibility to the premises	The premises is accessible from 06.20 mtr wide road on the Eastern Side	---
02.	Number of Entrances	02 Nos. One of 2.50 Mtr wide & 03.50 Mtr Height & another one of 01.90 Mtr wide on Eastern Side	---

Number of Staircase	No of staircase	03 Nos.			Staircase should be clear from any obstructions.
		Width of the staircase	01.10 Mtr	01.10 Mtr	
		Width of threads	00.29 Mtr	00.29 Mtr	
		Height of risers	00.16 Mtr	00.16 Mtr	
		No of risers per flight	11 No	11 No	
		Height of the hand drill.	0.90 Mtr	0.90 Mtr	
04.	Portable Extinguishers	12 nos. of 6 Kg capacity ABC type extinguisher and 02 Number of 4.5 kg Capacity CO2 Fire Extinguisher has been provided. All the extinguishers are BIS markings and are located at an easily accessible position without obstructing the normal passage.			Complied
05.	Hose reel hose system	05 nos. of Hose reel Hose of 19 mm size and of 30 mtrs length has been provided to reach the farthest point of each floor and shut off branch having a nozzle of 05 mm size.			Complied
06.	At the terrace tank level with minimum pressure of 3.5 kg/cm2	The system has been connected to booster pump of 750 LPM capacity. Further the system also has been connected to alternative source of power supply.			Complied
07.	Diesel Generator	01 of 82.5 KVA generator has been provided.			Complied.
08.	Terrace Tank	01 No 20000 Ltrs capacity basement tank has been provided.			Complied
09.	Escape routes	Direction in which the students/teachers have to move in the event of emergency has been indicated in the corridor/passage as a guide during evacuation.			Complied.
10.	Fire Order (Fire safety plans)	A notice board indicating the action to be taken by the employees in case of any emergency has been displayed along with the telephone numbers of Belagavi Fire station i.e 0831-2429441, 101 & 080-22971550, 22971500, 22971600 the telephone no's nearest ambulance services and police station.			Complied
11.	No Smoking board	COPTA Sec-4 direction of No Smoking area, smoking here is an offence board is written in the English & Kannada both languages and is displayed inside the entry/exit.			Complied
12.	Fire Siren	A fire siren has been installed in the premises to inform the students/teachers in case of a fire emergency and evacuate the area.			Complied

13.	Nominate One Fire Nodal Officer	1) Mr. Sanjeev J Rehimawale 2) Mr. Basavaraj Araganji 3) Mr. Fakruddin A Kamdod	Nominated
14.	Fire Fighting Training	1) Mr. Sanjeev J Rehimawale 2) Mr. Basavaraj Araganji 3) Mr. Fakruddin A Kamdod are undergone one day Basic training at Shaikh College Premises, Neharu nagar Belagavi Tq & dist-belagavi on 19/04/2025.	At least 40% of the Teaching and non Teaching staff should be got trained in basic fire fighting at R.A.Mundkur Fire & Emergency Services Academy, Bannerughatta Road, Bangalore or Regional training centre within 03 months from the date of issue
15.	<u>Fire Precautionary Measures</u> <i>A :- Explosive and flammable materials should not be stored in the store room, UPS room, Electrical panel area, class rooms, laboratory and electrical sum panel premises.</i> <i>B:-Accumulation of combustibile waste in and around the premises should be avoided.</i> <i>C:- The Exit ways shall be always kept clear without any obstruction.</i> <i>D:-Liquefied petroleum gas should not be stored in the building.</i> <i>E:- The doors shall not be kept locked/ latched during working hours and shall be free from obstruction.</i> <i>F:- During the class hours the class room door shall not be locked from inside to out side.</i> <i>G:- As per Honorable Supreme Court order all teachers and staff shall be trained to handle safety equipments, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the Fire Safety Day on April 14th of every year by conducting Fire Safety drills with co-ordination with the fire services department.</i>		

Under the above circumstance the Karnataka Fire & Emergency Services Department is issuing **“Fire Safety Compliance Report”** to **People’s Education Society & Trust’s, Shaikh Central School, Shaikh Campus, Nehru Nagar, Belagavi, Belagavi Taluka & District.** As they have complied all the recommendations as per reference 1. The staff should get trained in the basic fire fighting at R.A.Mundkur Fire & Emergency Services Academy, Bannerughatta Road, Bangalore or Regional training centre Hubballi.

This **“FSCR”** is valid for only one year from the date of issue and is renewable.



Yours Faithfully

(Signature)
25/04/25
District Fire Officer
Karnataka State Fire And Emergency Services
Belagavi-01.